



## CEMENTITIOUS FIREPROOFING PRODUCTS

---

### HIGH HUMIDITY CONDITIONS

In certain constructions, there are areas of possible high humidity, where the use of regular plaster based materials (Types 5GP™ or 5MD™) are not recommended. These areas may include:

Swimming Pools

Exercise Areas

Certain mechanical rooms, steam generation facilities

Water Treatment plants

Areas where potential high humidity conditions occur should be fireproofed with Portland cement-based products, such as Southwest Fireproofing Type 7GP™ or 7HD™.

Refer to data sheets for product details.