

Certificate of Compliance

Certificate Number 20091202-R11193
Report Reference 2009 December 2
Issue Date 2009 December 2

Page 1 of 1



**Underwriters
Laboratories Inc.**

Issued to: **Carboline Co.**

350 Hanley Industrial Ct
St Louis, MO 63144

*This is to certify that
representative samples of*


Mastic and Intumescent Coatings

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized
licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **ANSI/UL 263, "Fire Tests of Building Construction and Materials"**

Additional Information: Type Thermo-Sorb mastic intumescent coating with no topcoat required for Interior Conditioned Space. Finishing topcoat for Interior General Purpose, Types Carboguard 893 SG, Santile 655, Carbocrylic 3350 or Carbocoat 30R investigated per requirements of Standard UL 263 for use in Design Nos. D946, N619, X660, X661, X662.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute
Mona Couloute

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

Reviewed by:

Kenneth Rhodes
Kenneth Rhodes

Underwriters Laboratories Inc.